

**Government of Andhra Pradesh**

**A.P. State Disaster Response and Fire Services Department**

**Periodical Renewal Fire Certificate**

From:  
District Disaster Response & Fire Officer  
Andhra Pradesh, Satya Sai

To:  
The District Educational Officer, Sri Satya Sai District,

**File No: 32110/SSS/DFO/2026, Date:26/05/2026**

**Occupancy NOC RC Number: 11664/ATP/DFO/2020**

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **VIVEKANANDA MILLENNIUM SCHOOL, represented by B.N.Ramprasad, Sy NO.346-1,346-2,PULAKUNTA(P),HINDUPUR MANDAL,SRI SATYA SAI DISTRICT** - Regarding.

- Ref: 1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023  
2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.  
3. This Office NOC for Occupancy Rc No. 11664/ATP/DFO/2020, Dt.10/02/2020  
4. Renewal NOC For Occupancy 11664/ATP/DFO/2020, Dt.16/08/2024  
5. Online Application for Renewal NOC of B.N.Ramprasad, Sy NO.346-1,346-2,PULAKUNTA(P),HINDUPUR MANDAL,SRI SATYA SAI DISTRICT - Inspection report called for Regarding.  
6. Online Inspection Report submitted by Officers of this Department on 25-05-2026.

-- x --

The Management of VIVEKANANDA MILLENNIUM SCHOOL, represented by B.N.Ramprasad, Sy NO.346-1,346-2,PULAKUNTA(P),HINDUPUR MANDAL,SRI SATYA SAI DISTRICT has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.58600/- vide challan No. 11027387302026, Dated 22/04/2026 at CFMS, CFMS.

**VIVEKANANDA MILLENNIUM SCHOOL**

- This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
- The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
- The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **B.N.Ramprasad Sy NO.346-1,346-2,PULAKUNTA(P),HINDUPUR MANDAL,SRI SATYA SAI DISTRICT**, subject to the following conditions.

<b>Sl</b>	<b>As Builder</b>	<b>As Occupant</b>	<b>As Security Personnel</b>
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection. Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Addition / alteration, if any in the building may be verified by building authority.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3		Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

- This Periodical Renewal Fire Certificate is valid from 26/05/2026 to 25/05 2031.
- The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

## 6. Challan Info:

Challan Number	Challan Date	Challan Amount
11027387302026	2026-04-22	58600

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

This Renewal NOC is issued with conditions from Fire Safety Point of view only basing on recommendation of the Inspection committee and this Renewal NOC is not for claiming proprietary or ownership rights. Further, in case of any deviation noticed with respect to this NOC after issuance, the same Renewal 1 NOC shall be liable for cancellation at any time.

The Management has to maintain Fire Safety Measures and other Installations is good working condition at all time and responsibility of Fire Fighting equipment maintenance lies with the Management as seen & Tested by the committee at the time of Inspection.

This Renewal NOC valid for Five years only and It is the responsibility of the builder to apply for Renewal of No Objection Certificate, duly remitting the User Charges as per G.O.Ms.No.218, Home (Prison & Fire) Department, dated.22-12-2023, before expiry of this Renewal No Objection Certificate.

**"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"**

**"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"**

**"సురక్షిత పాఠశాలలు, సురక్షిత మైన్ ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై స్పృహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేద్దాము."**



Your Sincerely,

*[Handwritten Signature]* 26/5/2026

District Disaster Response & Fire Officer,  
Satya Sai District

***In case of emergency, please call 101 or 08556 – 220888 or 9963739702***

Copy to Management B.N.Ramprasad, VIVEKANANDA MILLENNIUM SCHOOL, Sy NO.346-1,346-

2,PULAKUNTA(P),HINDUPUR MANDAL,SRI SATYA SAI DISTRICT

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned